



JYOTI FIRE SERVICES™

Govt. Approved Fire Contractor of all kind of Fire sys. & Fire Brigade Works. ISO 9001:2008 Certified)
MAHARASHTRA FIRE SERVICE • LICENSE NO : MFS-LA/F-0370 D-0317

REGD. OFFICE : 17, ARUN CHAMBERS, GROUND FLOOR, NEXT TO A.C. MARKET, TARDEO, MUMBAI - 400 034.
ADMIN OFFICE : 243, SHREEJI CHAMBERS, 2ND FLOOR, TATA ROAD NO. 2, OPERA HOUSE, MUMBAI - 400 004.
TEL.: 022 - 2363 8712 / 2363 8679 / 2352 1735 / 2352 0328
E-mail : jyotifires@gmail.com • Website : www.jyotifireservices.com

Certificate

Dt.24/02/2021

Ref.No:JFS0686/2020-21

Client Name: M/s. MANAV MANDIR.

Address: Smt. N.R.P. Sheth Multipurpose High School, 10, Manav Mandir Road, Walkeshwar, Mumbai -400006.

The below mentioned Fire Extinguishers have been serviced & refilled for the above referred client in accordance with scheme of testing & inspection and found satisfactory as per relevant IS 2190.

Sr. No.	TYPE OF FIRE EXTINGUISHER	Class	Content	Test pressure kg/cm ²	Capacity	Quantity
01	Dry Chemical Powder (St. pressure type)	ABC	MAP-40	35	2 Kgs	03 Nos
02	Dry Chemical Powder (St. pressure type)	ABC	MAP-40	35	5 Kgs	13 Nos
	TOTAL					16 Nos.

Now complete equipments are free from defects in materials workmanship under normal use and service for 12 months from the date of supply but necessary periodical maintenance and services is required to put in smooth condition at all the time. Our obligation under this gurantee shall be limited to repair or to the replacement of any part of the said equipment found defective. This gurantee does not cover any damages or malfunction resulting from negligence, accident, fire, abuse or such other causes beyond our control. It is understood that soon as the use of the above equipment takes place, the date of usage shall be communicated to us.

For JYOTI FIRE SERVICES

AUTHORISED SIGNATORY



NATIONAL
FIRE PROECCION
ASSOCIATION

